§ 96.373

issue a notice of disapproval of the certification status of such monitoring system. For the purposes of this paragraph, an audit shall be either a field audit or an audit of any information submitted to the permitting authority or the Administrator. By issuing the notice of disapproval, the permitting authority or the Administrator revokes prospectively the certification status of the monitoring system. The data measured and recorded by the monitoring system shall not be considered valid quality-assured data from the date of issuance of the notification of the revoked certification status until the date and time that the owner or operator completes subsequently approved initial certification or recertification tests for the monitoring system. The owner or operator shall follow the applicable initial certification or recertification procedures in §96.371 for each disapproved monitoring system.

§96.373 Notifications.

The CAIR designated representative for a CAIR NO_X Ozone Season unit shall submit written notice to the permitting authority and the Administrator in accordance with §75.61 of this chapter.

 $[70~{\rm FR}~25382,~{\rm May}~12,~2005,~{\rm as~amended}~{\rm at}~71~{\rm FR}~25395,~{\rm Apr.}~28,~2006]$

§96.374 Recordkeeping and reporting.

- (a) General provisions. The CAIR designated representative shall comply with all recordkeeping and reporting requirements in this section, the applicable recordkeeping and reporting requirements under §75.73 of this chapter, and the requirements of §96.310(e)(1).
- (b) Monitoring plans. The owner or operator of a CAIR NO_X Ozone Season unit shall comply with requirements of §75.73(c) and (e) of this chapter and, for a unit for which a CAIR opt-in permit application is submitted and not withdrawn and a CAIR opt-in permit is not yet issued or denied under subpart IIII of this part, §§96.383 and 96.384(a).
- (c) Certification applications. The CAIR designated representative shall submit an application to the permitting authority within 45 days after completing all initial certification or recertification tests required under

§96.371, including the information required under §75.63 of this chapter.

- (d) Quarterly reports. The CAIR designated representative shall submit quarterly reports, as follows:
- (1) If the CAIR NO_X Ozone Season unit is subject to an Acid Rain emissions limitation or a CAIR NO_x emissions limitation or if the owner or operator of such unit chooses to report on an annual basis under this subpart, the CAIR designated representative shall meet the requirements of subpart H of part 75 of this chapter (concerning monitoring of NO_X mass emissions) for such unit for the entire year and shall report the NO_X mass emissions data and heat input data for such unit, in an electronic quarterly report in a format prescribed by the Administrator, for each calendar quarter beginning with:
- (i) For a unit that commences commercial operation before July 1, 2007, the calendar quarter covering May 1, 2008 through June 30, 2008;
- (ii) For a unit that commences commercial operation on or after July 1, 2007, the calendar quarter corresponding to the earlier of the date of provisional certification or the applicable deadline for initial certification under §96.370(b), unless that quarter is the third or fourth quarter of 2007 or the first quarter of 2008, in which case reporting shall commence in the quarter covering May 1, 2008 through June 30, 2008;
- (iii) Notwithstanding paragraphs (d)(1)(i) and (ii) of this section, for a unit for which a CAIR opt-in permit application is submitted and not withdrawn and a CAIR opt-in permit is not yet issued or denied under subpart IIII of this part, the calendar quarter corresponding to the date specified in §96.384(b); and
- (iv) Notwithstanding paragraphs (d)(1)(i) and (ii) of this section, for a CAIR NO_X Ozone Season opt-in unit under subpart IIII of this part, the calendar quarter corresponding to the date on which the CAIR NO_X Ozone Season opt-in unit enters the CAIR NO_X Ozone Season Trading Program as provided in §96.384(g).
- (2) If the CAIR NO_X Ozone Season unit is not subject to an Acid Rain emissions limitation or a CAIR NO_X